

GOVERNMENT OF PUDUCHERRY
RAJIV GANDHI GOVERNMENT WOMEN AND CHILDREN HOSPITAL
[O/o. AB-PMJAY and Quality & Safety]
ELLAIPILLAICHAADVY, PUDUCHERRY – 605 005.

NIQ No.:RGGWCH/AB-PMJAY/Spl.Ward Elec.Work/2026-27 Date: 11-08-2026.

**NOTICE INVITING QUOTATIONS FOR PROVISIONING OF ELECTRICAL
WIRING AND A.C. POWER SUPPLY IN SPL. WARD AT 4TH FLOOR**

Quotations are invited for Provisioning of Electrical Wiring and A.C.Power Supply in Special Ward at 4th Floor of this Hospital as per annexure.

2. Under the terms and conditions detailed below, quotations may be submitted on or before 21.08.2026 till 4.00 p.m. by post/in person furnishing the competitive rates, for the works as per Annexure, in a closed envelope addressed to the "Medical Superintendent, Rajiv Gandhi Government Women and Children Hospital, Ellaipillaichavady, Puducherry – 605 005, and with "Quotation for Provisioning of Electrical Wiring & A.C. Power Supply" marked on it:

- i. The rates quoted by the contractor shall be for the works as mentioned in the Annexure which includes the materials and other items required for the works. The rates quoted shall be inclusive of insurance charges, if any. No insurance charges, like transit insurance, etc., will be paid by the purchaser. The contractor shall be solely responsible for the safe delivery of goods in good condition. However, GST may be charged as applicable.
- ii. The rates once quoted and approved shall be final and valid for one year from the date of finalization of the lowest bidder. No violation will be accepted in this regard.
- iii. The materials items to be used in the work shall conform to I.S. Standard.
- iv. The works to be carried out shall be strictly in accordance with the specifications mentioned in the work order. Any item, which is not up to the specification or is damaged, will have to be reworked by the contractor at their own cost.
- v. The work shall be commenced immediately after the issue of work order in the place as mentioned in the work order at Rajiv Gandhi Government Women and Children Hospital, Ellaipillaichaavady, Puducherry - 605 005, by the safest mode. If work is not commenced within two days, the order placed with L1 shall stand cancelled and be placed with L2 without any notice to L1. No further correspondence shall be entertained from L1 and this Hospital will not take any responsibility for any loss.
- vi. The details of company's account for payment through the Electronic Clearing Service (ECS) and other important nos. under the GST regime and PAN shall be mandatorily mentioned in the quotation.
- vii. The quotations received either by post or in person after the due date and time shall be summarily rejected. The quotations received for part of the work execution will also summarily be rejected.

3. The Payment through the ECS will be made after the completion of works in good condition and after the receipt of pre-receipted, stamped bill in duplicate.


Medical Superintendent

To

1. For Display in Notice Board.
2. For Hosting in DHFWS / Hospital Website.

**Provision of A.C. Power Plug Point wiring for Special Ward in
4th Floor, RGGW&CH, Puducherry. (Including materials)**

Sl. No.	Items	Quantity
WORK -I		
1	Supply and fixing of 35 Sq.mm. x 4core U.G. Aluminium armoured cable	75 Mtrs.
2	Labour charges for 35 Sq.mm Cable end termination work including gland and lug.	2 end
3	Supply and fixing of 14swg Copper Conductor for Earth Connection	15 Mtrs
4	Supply and fixing of 125 amps 4 Pole Isolator	1 No.
5	Supply and fixing of 32 amps single pole MCB	6 Nos.
6	Supply and fixing of 4 Sq.mm copper wire 2 run, 1.5 Sq.mm copper wire 1 run, 25mm PVC Pipe, Clamp and accessories.(DB to Room No.522 A/C Wiring)	29 Mtrs.
7	Supply and fixing of 4 Sq.mm copper wire 2 run, 1.5 Sq.mm copper wire 1 run, 25mm PVC Pipe, Clamp and accessories.(DB to Room No.517 A/C Wiring)	52 Mtrs.
8	Supply and fixing of 20 amps A/C Metal Gland Socket with MCB Box	2 Nos.
9	Supply and fixing of 4 way 3 Phase Double Door DB Box	1 No.
10	Supply and fixing of 100 amps TPN Cubical switch with fuse link. (Alteration Work)	1 Job
WORK-II		
1	Supply and Fixing of 150sq.mm x 3.5core U.G. Aluminium cable	53 Mtrs.
2	Labour charges for 150sq.mm Cable end termination work including gland and lug.	2 end
3	Supply and fixing of 250 Amps TPN Cubical switch with Enclosure Box including fuse link. (Alteration work)	2 Nos.


Medical Superintendent